

Certificate

Product certificate
K-0227917-1

kiwa

Valid from **2026-05-15**

Replaces

Page

1 of 2

Ball Valves

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Belimo Automation AG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K604:2022 "Stop- and connecting cocks", which covers the requirements of

EN 13828:2025: "Building valves – Manually operated copper alloy and stainless steel ball valves for potable water supply in buildings"



Wim van Loon
Managing Director Nederland

Publication of this certificate is allowed.

Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.



Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
NL.Kiwa.Info@kiwa.com
www.kiwa.com

BELIMO Automation AG
Brunnenbachstrasse 1
8340 Hinwil
Switzerland
www.belimo.com

Ball Valves

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate;

| Article no. valve | DN size | Connecting ends | Electric actuator |
|-------------------|---------|-------------------|-------------------|
| C215QPW-N | DN 15 | ½" inner thread | CQ24A |
| R215PW-N | DN 15 | ½" inner thread | LR24A |
| R220PW-P | DN 20 | ¾" inner thread | LR24A |
| R225PW-Q | DN 25 | 1" inner thread | LR24A |
| R232PW-Q | DN 32 | 1 ¼" inner thread | SR24A |
| R240PW-R | DN 40 | 1 ½" inner thread | SR24A |
| R240PW-R | DN 50 | 2" inner thread | SR24A |

Fitness for contact with drinking water


These products are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The products shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the Kiwa Watermark; "KIWA .

Place of the mark:

- on the body.

Compulsory specifications:

- manufacturers name or mark, on the body;
- nominal size: "DN", on the body;
- marking according to EN 13828.

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

Ball valves are designed to shut off, if desired, temporarily, conduit pipes of drinking water installations intended for transporting drinking water with a maximum pressure of 1000 kPa and a water temperature with a maximum of 65 °C. Using the products in water installations with a water temperature up to 90 °C is possible. However, this may influence the durability of some parts.

RECOMMENDATIONS FOR THE CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Belimo Automation AG

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.