

Notes for project planning



Introduction to MP-Bus Technology

Edition 2025-03/C



Table of contents

Introduction to MP-Bus Technology			
Connection to MP client			
MP node connection	5		
Cable	7		
Cable lengths	9		
Override control function	12		
Tools and accessories	13		
Overview of MP-Bus-capable devices	14		
MP-Bus function profiles	15		
Bus fail action	19		
Belimo Assistant 2: Configuration	20		
Belimo Assistant 2 as diagnostics tool	22		
Belimo Assistant 2: Connection possibilities			
Diagnostics options with ZTH EU			
MP specifications			
MP Partner Program	29		



Introduction to MP-Bus technology

MP-Bus

3

MP node

Network topologies

The MP-Bus is the Belimo Single-Client/Multi-Server bus. Up to 8 MP nodes can be connected to one MP client device. 16 devices can be connected if only actuators of the latest design (e.g. ..-MPL) are used. The specifications of the respective MP partner apply.

Generic term for MP-capable actuators, sensors and sensor/actuator combinations (e.g. Energy Valve, 6-way-PI-Valve).

There are no restrictions regarding network topology. Star, ring, bus or hybrid forms are permissible.



Sensor interface

MP-Bus mode

- I	MP-Client	
S -Server		Server-S
S -Server	—	Server-S
S - Server		Server- S
S -Server		Server- S

Sensor connection

One sensor per MP node can be connected in MP-Bus mode. The sensor value is recorded with its raw value (Ω , mA, 0/1) and transferred by the MP node in digital form to the MP-Bus. Scaling and evaluation of the sensor value are performed in the MP client or DDC controller, respectively.

Active sensors (output DC 0...10 V) and switches (0/1) can be connected to the MP nodes. Passive resistance sensors (e.g. Pt1000, NTC10K) can also be connected. Please observe the respective product information/the data sheet of the MP node.



Restrictions

MPL actuators

These actuator types do not have any options for a sensor connection.

2-Way-EPIV

On actuator types with the designation EP..R + MP / EP..R-KMP as well P6..W ..- MP / P6..W ..- KMP, no passive sensors can be connected.

Connection to MP client

Definition

MP clients are MP cooperation nodes (PLC or DDC controllers with MP interface), e.g. Wago, Saia-Burgess, etc., or MP gateways (for connection to a field bus system), e.g. UK24MOD, UK24BAC, etc.

The Windows version of Belimo Assistant 2 is also an MP client.







Belimo MP gateway

MP node connection

Standard

MP nodes are usually connected on the basis of the connections. Wire 1 GND/black Wire 2 24 V/red Wire 5 MP/orange

MP(L) actuators



The connection of some actuator types differs from the standard MP nodes. Please refer to the product-specific data sheet. Examples:

Exceptions

Belimo Energy Valve[™]





with local power supply



6

Belimo Energy Valve[™]

with Ethernet on the flow sensor





MP L

with local power supply

6-way-PI-Valve

PR..A-S2-BAC





Cable

7

One cable for communication and power supply

Communication and power supply can be carried in the same cable on the MP-Bus. GND and AC/DC 24 V are used to ensure the power supply to the MP nodes. The MP client communicates with the connected nodes via the MP communication connection, which references the same GND as the power supply.



Neither special cables nor terminating resistors are required. An MP-Bus connection can be established using conventional installation cables, but special bus cables are available for simplified wiring.

Example of flat ribbon cable

Flat ribbon cable from Woertz with adapter for MP-Bus connection of MP nodes and sensors.



Contact: www.woertz.ch

8

Example of a connecting board

With the ZFP2-MP connecting board it is possible to connect 2 MP nodes, including 2 sensors, to the MP-Bus by using the connector socket. Preassembled and colour-coded connector plugs on the MP nodes prevent wiring errors and ensure fast installation and commissioning. The RJ12 diagnostics connector can be used to configure or check the MP nodes independently of the MP-Bus.



The connecting board is optionally installed together with either the EXT-WR-FP20-MP (IP20) or EXT-WR-FP65-MP (IP65) wiring box.



For more information on the connecting board and wiring box, visit your local website.

9

Cable lengths

Definition of cable length

The cable length of an MP network is limited by the following factors:

- Sum of the power consumption of the connected MP nodes
- Type of power supply (AC or DC via MP-Bus/AC or DC local power supply)
- Cable cross-section

The Belimo MP-Bus cable length calculator is available on the Belimo website for calculating the maximum cable length for the complete MP-Bus product range.

Determination of the maximum cable length for AC 24 V power supply



Add up the power rating outputs [VA] of the MP nodes used and read off the corresponding cable lengths in the diagram.



Example:

Connected to the MP-Bus: 1 x NM24A-MP, 1 x SM24A-MP, 1 x LMV-D3-MP... and 1 x NV24A-MP-TPC

Power rating output total: 5.5 VA + 6 VA + 4 VA + 4.5 VA = 20 VA

To be read out in the set of curves:

- For cables with wire Ø 0.75 mm²: Cable length 30 m
- For cables with wire Ø 1.00 mm²: Cable length 40 m
- For cables with wire Ø 1.50 mm²: Cable length 60 m
- For cables with wire Ø 2.50 mm²: Cable length 100 m

Determination of the maximum cable length for DC 24 V power supply



Add up the power consumption [W] of the MP nodes used and read off the corresponding cable lengths in the diagram.



Example:

Connected to the MP-Bus:

1 x NM24A-MP, 1 x SM24A-MP, 1 x LMV-D3-MP... and 1 x NV24A-MP-TPC

Total power consumption: 3.5 W + 4 W + 2 W + 3 W = 12.5 W

To be read out in the set of curves:

- For cables with wire Ø 0.75 mm²: **Cable length 60 m**
- For cables with wire Ø 1.00 mm²: **Cable length 80 m**
- For cables with wire Ø 1.50 mm²: Cable length 120 m
- For cables with wire Ø 2.50 mm²: Cable length 180 m

Local power supply on site

If the MP nodes are supplied locally via a separate transformer with AC/DC 24 V, then cable lengths can be considerably increased. Independent of the power rating of the connected MP nodes and independent of the wire \emptyset of the MP wiring, the cable lengths are in accordance with the table.



Example Power supply unit ZN230-24MP

The supply on site can be provided by any commercially available transformer. Belimo also offers a device that is especially suitable for on-site supply. The MP nodes are supplied locally with AC 24 V by the ZN230-24MP. This means that long MP-Bus lines can be implemented.

Sensors can be connected to the MP nodes via ZN230-24MP. The ZTH EU can also be connected to the MP node via ZN230-24MP. Communication with the MP network is disconnected as soon as an MFT service tool is plugged into the "Tool" connector socket. This prevents data collisions.



Override control function

Restrictions

It is possible to have the override control function have a local effect on the MP node while it is running on the MP-Bus, i.e. controlled digitally by the MP-Bus gateway or by a DDC cooperation node via the MP-Bus.

- Analogue override control functions only if the actuator is supplied with AC 24 V.
- The override control can be used only if the sensor integration is not used at the same time on the same MP node.
- The override control function is not available or only partially available for individual MP-Bus-capable actuator types (e.g. Energy Valve, 6-way-PI-Valve).

Analogue override control in an application with the UK24MOD gateway.

Example of override control for an MP client

Note:

For volume and flow controllers, MAX corresponds to the set maximum volumetric flow V'_{max} .

A diode is absolutely necessary for moving the volume or flow controller to the override open position.



^{*} Not available with DC 24 V supply.

Tools and accessories



ZTH EU



ZIP-BT-NFC



MFT-C



ZN230-24



For the operation of the MP-Bus, various accessories are available for the installation, configuration, operation and maintenance of the MP network.

Belimo Assistant 2 for configuration of designated MP nodes via NFC.

efficient commissioning as data can be read and written in powerless state
 simple, wireless connection via integrated NFC interface

Install the Belimo Assistant 2 via "Google Play" or "App Store". The Windows version can be downloaded from the Belimo website. Prerequisite:

- NFC-capable or Bluetooth-capable smartphone or tablet

- PC with USB input (for the Windows version)

Service tool for configuration and communicative Belimo actuators/VAV controllers and HVAC performance devices. The ZTH EU is powered by the MP node when connected to the service socket.

The ZTH EU can be used as follows:

- for configuration of MP nodes
- as USB/MP-Bus level converter (ZIP function)

See also "Tool Connections" document on your local website.

BT/NFC converter for configuration via Bluetooth. Supply via integrated rechargeable battery, incl. USB charging cable and retaining strap.

The converter enables Belimo devices (NFC-enabled actuators, etc.) to be operated with an iPhone or Android device. Data transmission between smartphone and Belimo device is wireless with a Bluetooth[®] BLE or NFC connection.

Adapter for ZTH EU service tool

Simple connection via quick-release terminals, configuration of actuators with ZTH EU.

The actuator is connected to the MFT-C adapter using the quick-release terminals. The Belimo ZN230-24 plug-in power supply unit plugged into the jack socket supplies the connected actuator with voltage.

See also "Tool Connections" document on your local website.

Plug-in power supply for the MFT-C.

Overview of MP-Bus-capable devices

MP nodes from Belimo

You can find an up-to-date overview of all MP-Bus-capable devices on your local website.



Third-party MP nodes are devices which were not developed by Belimo but which can nevertheless be used together with the MP-Bus. The devices are not supported by all MP partners. Therefore, please check the respective documentation of the MP partners.

These MP-I/O modules and sensors are manufactured and distributed by Walter Müller AG (Switzerland).

The module is applied when analogue or digital signals from/to field devices such as sensors, switches, frequency converters, circuit breakers, etc. are to be connected to the MP-Bus.

The Analogue Signal Transmitter is used to measure and output analogue variables via the MP-Bus.

Multi sensor for pressure, temperature and humidity that can be connected to an MP network as an independent MP-Bus participant.

In order for the MP client to be able to read out the measured values for pressure, temperature and humidity, the necessary MP commands must be implemented in the MP client. Walter Müller AG provides a corresponding MP data profile.

Further MP-Bus-capable modules and sensors as well as contact details can be found at <u>www.wmag.ch</u>.

Third-party MP nodes

Modules and sensors from Walter Müller AG

UST-5 I/O





Multi sensor PTH



MP-Bus function profiles

Overview	MP function profiles define the interface and its scope (data points, parameters, functions) of an MP node.		
	A distinction is made between the fo – MP profile – MPL – Air/water module – VAV/EPIV – Fire protection – Data pool device	ollowing MP-Bus data profiles:	
MP function profiles	The MP function profiles include req comments. The available MP profile	uired commands, optional commands, and as are explained in detail below.	
Implementation of data profiles	Depending on the MP partner, the integrated. The function block desc product description of the Belimo ga	ne data profiles are sometimes not fully pription of the respective MP partner or the ateway used must therefore be consulted.	
MPL profile	The MPL profile is the simplest varia	ant of an MP profile.	
Profile overview			
	Setpoint [0100%]	PL profile Rel. position [%]	
	Addressing	Serial number	
Typical actuator variants	Valve actuators Damper actuators	CQ24A-MPL (-T), KR24-MPL CM24-MPL-(L) or (R)	

Air/water actuators

Control of air dampers and valves.



Examples

VAV/EPIV

Control of VAV controllers and electronic pressure-independent characterised control valves (EPIV)



Examples

VAV controllers: 2-way EPIV:

Valve actuators:

...MV-D3-MP, VRP-M, ...HV-D3-MP EP0..R+MP, EP0..R+KMP, P6..W..E-MP, P6..W..E-KMP

..R24A-MP, ..V24A-MP, ..VK24A-MP, ..RF24A-MP / MFT, PR..A-BAC-..



Subject to technical modifications

Support MP profile MP client

Control of air dampers and valves.

	UK24MOD	UK24BAC	MP co-operation partners
Air / water actuators		•	■ 1)
VAV / 2-way EPIV	•	•	■ 1)
Fire protection	•	•	∎ 1)
MPL profile			1)
Data pool devices		-	1)

 $^{\mbox{\tiny 1)}}$ Clarify the scope of functions directly with the respective MP partner.

Note

The devices that are supported by each MP cooperation partner can be viewed in the "<u>MP Cooperation Partner List</u>" on the Belimo website.

Bus fail action

Definition

Example

For MP actuators, so-called bus fail actions can be set with the windows version of Belimo Assistant 2. This allows you to define how the actuator is to behave if communication with the MP client is lost. In the event of a loss of MP communication, the actuator detects this within defined timeout and moves to the preset position.

If bus communication fails, the valve actuator of a heating coil is opened completely (frost protection function).

Device parameters		\otimes
Communication		
MP Address	MP1	~
Bus Fail Action	Last Value	^
Last Value		
Open		
Close		
• Mid.		
Fast Close		

Possible settings Bus fail action

Actuator type	Possible bus fail actions, adjustable with the windows version of Belimo Assistant 2	Default setting (factory setting)
24 A-MP	 Last setpoint (actuator stops) Open (actuator opens completely) Close (actuator closes completely) Fast close (actuator closes completely) 	– Last setpoint (actuator stops)
MV-Dx-MP	 Last setpoint (control mode) Open (actuator opens completely) Close (actuator closes completely) Min./V'min Max./V'max Fast close (actuator closes completely) 	– Last setpoint (control mode)

Belimo Assistant 2: Configuration

Belimo Assistant 2 offers the following functions.

MP client operation

- Configuration of the actuators via MP-Bus
- Specification of setpoints for simulation of the actuators via MP-Bus
- Reading in the sensors connected to the MP actuator
- Recording of graphic trends

BELIMO 🗑 Home	🗟 Help 💥 Settings				O Connect device
C LR24A-MP					01941-00104-142-136
Data		Une	•	Workflows	
Relative Setpoint	Relative Position			↓ Setup	>
0	0			(iii) Copy/Paste Configuration	>
Control Signal	Feedback US			Live Trend	>
Modulating	Relative Position 2-10 V	and the second se		$\left\ \frac{1}{2} \right\ ^2$. Device Management	>
				Actions	
				Export Configuration	>
				General Information	
		Health Status 🧭		③ Site Information	>
Device parameters				i Product Information	>
Health	•				
Operating Time	ОК				
Actuator	ок				

MP-Bus scan

After starting up, select gateway. Belimo Assistant 2 checks the MP network with the bus scan function and displays all MP nodes that are integrated on the MP bus line.

BELIMO	📜 Home 💿 Help 💥 Se	ettings		
\odot				
			Choose a gateway through which you with your Belimo device. Searching for ga BELIMO ZTH Serial Port (COI	ould like to communicate teways 432)
BELIMO	👿 Home 💿 Help 💥	Settings		
\bigcirc				
			BELIMO ZTH Serial Port	(COM32)
			Searchin	g for devices
			MP1 LR24A-MP	01941-00102-142-160
			O MP2 NMV-D3-MP	01529-00048-158-140
			MP3 GK24A-MP	01835-20047-142-184

MP client simulation function

The following options are available in Belimo Assistant 2:

- Control of the connected MP nodes, independent of an MP client, and read the sensor values (setpoint tool).
- Readout and display of the setpoint signal of the MP client and the behaviour of the connected MP nodes (setpoint Y).

Recording a trend

Example of an LM24A-MP with passive sensor connected.

- 1 = Actuator setpoint
- 2 = Actuator actual value





Note on sensor values

Sensor values are acquired with their raw value ($\Omega,$ mA, 0/1) and sent accordingly to the connected MP client.

Belimo Assistant 2 as diagnostics tool

Monitor function

Checking MP communication with the MP monitor tool.

🐼 C:\Program	me\Belimo	\Belimo F	PC Too	I V3.21	mp_mon	.exe			- 0	×
MP-MONITOR	<u3.1></u3.1>	C0M1	MODE	3 D	: disab	le	BACKSPACE:	clear	ESC: exi	it
Address Series-No Override Sty Soncor M	t Act_po M Stato	Type s Range Adapt/	Act Snyc/1	t_vol Iost	Vnom	Desi	ignation Min_Max	Posit t_run	ion Strin Directi	ng Lon
MP1 00626-20013- NONE 0 0	128-053 27% 0009010	NU24- 23.7mm	MFT2			AVY2	24-nff 0%_100%	60s	G₩	
МР2 00609-30251- NONE 0 0	142-136 0% 0000000	LM24A 93.00	- M P				0×_100×	40s	CM	
MP3 Ø1234-Ø5678- NONE ×_ Ø Ø	146-079 0000000	LMU-D 95.1°	2-MP	0×	600nJ	АВС/ Ъ	~01 - Size25 0×_100%	0 Floor 150s	1b C₩	
MP4?										

The monitor function can be used to monitor and evaluate the MP-Bus communication. The following two functions are available for this purpose:

F1: MP logging at command level

Monitoring of the MP commands sent from the MP client to the MP nodes.

MP-MONITOR V3.8.0.3									1				×
MP-MONITOR (U3.8)	COM19 MODE:	1 D: (lisable		BACK	SPAC	:E:	clea	ar	E	SC:	ex	it
COMMAND	(###>	ADR D	L D2 D3	D4	D5	D6 f	D1	D2	D3	D4	D5	D6	D7
GET_SERIESNO	<050>	MP2				5	02	E7	00	96	32	8E	87
GET_RELATIVE	(041)	MP3				5	00	00	00	00			
GET_SERIESNO	<050>	MP4				5	05	10	C3	64	33	91	6F
GET_RELATIVE	(041)	MP4				S	ØB	B9	ØB	B8			
GET_RELATIVE	(041)	MP5				5	00	00	00	00			
GET_RELATIVE	<041>	MP6				S	00	00	00	00			
GET_VRELATIVE	<057>	MP6				S	00	00	00	00			
GET_RELATIVE	(041)	MP1				S	00	ØB	00	00			
GET_MIN_MID_MAX	<059>	MP1				I	E ØB						
GET_RELATIVE	<041>	MP2				S	13	E6	00	00			
GET_RELATIVE	(041)	MP3				S	00	00	00	00			
GET_RELATIVE	(041)	MP4				S	ØB	B9	ØB	B8			
GET_RELATIVE	<041>	MP5				S	00	00	00	00			
GET_RELATIVE	(041)	MP6				S	00	00	00	00			
GET_URELATIVE	<057>	MP6				S	00	00	00	00			
GET_M_M_STATE	<026>	MP6				S	00						
GET_RELATIVE	〈041〉	MP1				S	00	ØB	00	00			
GET_MIN_MID_MAX	<059>	MP1				I	E ØB						
GET_RELATIVE	(041)	MP2				5	12	3F	00	00			
GET_RELATIVE	(041)	MP3				S	00	00	00	00			
GET_SERIESNO	<050>	MP3				5	03	FA	27	63	32	9C	ÂÂ
GET_RELATIVE	(041)	MP4											

F3: MP logging at application level

Monitoring of the connected MP nodes and their current parameters and process values.

MP-MONITOR V3.8.0.3				
MP-MONITOR (U3.8)	COM19 MODE3	D: disable	BACKSPACE: clear	ESC: exit
Address Series-No Override Stpt Act_r Sensor MM State	Type pos Range Act_v Adapt/Snyc/Tes	Des: vol Vnom st	ignation Pos Min_Max t_run	ition String Direction
MP1 01308-00006-161-200 0 0%				
MP2 00743-00150-142-135 0 0% 00000000			0%_100%	
MP3 01018–10083–156–170 0% 00000000			0×_100×	
MP4 01308-50020-145-111 30% 00000000			30%_100%	
MP5 01140-00101-143-158 0 0% 0000000			0×_ 70×	
MP6 01003-00053-157-156 0% 00000000	0%	60m3 h	Øx_ 83x	
MP7?				
MP8				

Belimo Assistant 2 (Windows version): Connection possibilities





Belimo Assistant 2 (MP client) at gateways with tool connection

When Belimo Assistant 2 is connected to the tool connector socket, the MP client is automatically deactivated (disabled) and Belimo Assistant 2 is recognised as the MP client. The higher-level bus system (e.g. BACnet, Modbus) becomes inactive.

As soon as the cable is removed from the tool connector plug, the gateway is operated (enabled) once again as MP client; the higher-level bus system activates the MP nodes and reads out their values once more.

Additional connection possibilities

For other connection options, see the "Tool connections" document on your local website.

Diagnostics options with ZTH EU

The following diagnostics options are available with the ZTH EU:

- Checking the power supply
- MP tester
 - Checking the MP-Bus levels
 - Telegram counter

Checking the power supply

The ZTH EU can be used to test the AC 24 V (III protective extra-low voltage (PELV)) power supply including the half-wave ratio (VHW) of the Belimo MP-Bus nodes.





MP tester

MP-Bus level

With the MP tester function, the ZTH EU offers the possibility of determining the MP-Bus level at both the MP client and the MP server nodes. In addition, MP-Bus communication can be checked by counting the telegrams.

The MP signal levels from the MP client and the MP server nodes are measured against GND and compared with the limit values of the protocol specification.



The number of telegrams is recorded and the correctness of telegrams



(checksum) is checked.

Frame counter

MP specifications

Brief description of MP communication

Communication	Single-Client/Multi-Server The server (MP node) answers only to commands from the MP clients
Data transmission	Bi-directional, half-duplex Communication takes place via the MP/U5 connection, referenced to GND.
Communication parameters	1200 baud, 8 data bits, 1 start bit, 1 stop bit, no parity
Number of participants on the MP-Bus	The communication protocol is enabled for 1 MP client and 18 (16) servers (MP nodes).

MP signal level

MP communication takes place on a carrier signal of 18 V between the ground and wire 5. The signals for commands from the MP client and the corresponding answer look like this (see figure below).



Measurement conditions

All signals are measured from U5 to GND.	min.	normal
/oltage level high Request and answer	>11 V	12.5 V
/oltage level low Request (MP client)		>2.5 V

/oltage level low	>4.5 V
Answer (MP server)	



The more actuators to be operated on the bus and the more sensors for readout at the MP nodes, the longer the polling intervals on the Belimo MP-Bus. The resulting cycle times on the MP-Bus are shown in the curve below.



Note

Cycle times can be reduced by prioritizing the MP commands (high, medium, low).

MP Partner Program



Advantages of MP cooperation

With the MP Partner Program, Belimo offers system integrators the opportunity to become MP cooperation partners.

Belimo makes the MP specifications available to all interested manufacturers of control devices in order to implement a corresponding MP interface in terms of hardware and software in their own DDC controllers.

The MP partner benefits from the following advantages:

- It receives a certificate that the DDC used complies with the MP standard.
- It may use the MP logo.
- It is officially listed by Belimo as a cooperation partner for MP solutions in the MP cooperation list.
- It experiences an increase in quality due to:
 - Protection of the end customer against malfunctions
 - Avoidance of quality problems (no conformity tests on the plant necessary!)
 - Avoidance of reputational damage

Furthermore, new MP-Bus products are made available to MP partners for implementation at an early stage. This ensures that they are already available with your DDC solution at the time of market launch.

Request MP cooperation

If this is of interest to you, please contact your local Belimo representative.

All inclusive.

Belimo is the global market leader in the development, production, and sales of field devices for the energy-efficient control of heating, ventilation and air-conditioning systems. The focus of our core business is on damper actuators, control valves, sensors and meters.

Always focusing on customer value, we deliver more than only products. We offer you the complete product range for the regulation and control of HVAC systems from a single source. At the same time, we rely on tested Swiss quality with a five-year warranty. Our worldwide representatives in over 80 countries guarantee short delivery times and comprehensive support through the entire product life. Belimo does indeed include everything.

The "small" Belimo devices have a big impact on comfort, energy efficiency, safety, installation and maintenance.

In short: Small devices, big impact.





