

Product information

VAV-Compact MP

Pressure sensor, digital VAV controller and damper actuator as communicative compact solution for pressure-independent VAV and CAV systems in the comfort zone

- Control (0) 2...10 V or via MP-Bus
- MP-Bus: Control devices with MP interface,
- Gateway: BACnet / Modbus
- DCV Fan Optimiser function in DDC
- Conversion of sensor signals
- Service socket for operating devices
- NFC interface for Smartphone App



| Brief description | | | | | | | | |
|--------------------------------------|--|---|--|--|--------------------------------|--|--|--|
| Application | The VAV-Comp of VAV units in | oact with its PI o the comfort zo | control characteristic is used | d for the pressure-independe | ent control | | | |
| Volumetric flow measurement | The integrated The maintenar zone: resident | The integrated D3 differential pressure sensor is also suitable for very small volumetric flows. The maintenance-free sensor technology enables a wide range of applications in the comfort zone: residential construction, office, hospital, hotel, cruise ship, etc. | | | | | | |
| Actuator | A variety of ac manufacturer | tuator versions for the differen | (rotary or linear actuators) t VAV unit designs. | are available to the VAV unit | | | | |
| Control function | Volumetric flov loop). | w (VAV/CAV) or | position control (Open Loo | op for integration in external | VAV control | | | |
| VAV (VVS) - Variable volumetric flow | Demand-depe variable (0/2 energy-saving | Demand-dependent specification of the volumetric flow V' _{min} V' _{max} via modulating reference variable (0/210 V / MP-Bus), e.g. room temperature/CO ₂ controller, DDC or bus system, for energy-saving air conditioning of individual rooms or zones. | | | | | | |
| CAV (KVS) - Constant volumetric flow | Step mode (via switching contacts) for constant volume applications CLOSE / V' _{min} / V' _{mid} / V' _{max} / OPEN. | | | | | | | |
| DCV - Demand Controlled Ventilation | Via Bus Client or MP-Partner solution with integrated Optimiser function. | | | | | | | |
| Bus mode | Belimo MP devices (VAV / damper and valve actuators) can be connected via the MP-Bus to an MP client device: MP Partner solution: DDC controller with integrated MP-Bus protocol Gateway for integration in BACnet and Modbus applications In Bus mode, an additional sensor (010 V / passive), e.g. temperature, or a switch for the higher-level system can be overridden. See separate MP-Bus documentation at www belimo com | | | | | | | |
| Operating and service devices | Smartphone Belimo Assistant App: Contact-free operation via the integrated NFC interface. Service tool ZTH EU. PC-Tool service socket: Local plug-in or via MP-Bus. | | | | | | | |
| Electrical connection | The connectio | n is made using | g the integrated connecting | g cable. | | | | |
| Sales, assembly and setting | The VAV-Comp adjusted and o for this reason | bact is mounted calibrated accor | d by the VAV unit manufactur rdingly. The VAV-Compact is | urer (OEM), and the applicati s sold exclusively via the OEM | on is 1 channel | | | |
| Type overview | Туре | Torque | Power consumption | For wire sizing | Weight | | | |
| MP versions | LMV-D3-MP | 5 Nm | 2 W | 3.5 VA (max. 8 A @ 5 ms) | Approx. 500 g | | | |
| | NMV-D3-MP | 10 Nm | 3 W | 5 VA (max. 8 A @ 5 ms) | Approx. 700 g | | | |
| | SMV-D3-MP | 20 Nm | 3 W | 5.5 VA (max. 8 A @ 5 ms) | Approx. 830 g | | | |
| | LHV-D3-MP | 150 N | 2.5 W | 4.5 VA (max. 8 A @ 5 ms) | Approx. 550 g | | | |
| OEM version | In addition to variants produ and labelling c manufacturer Designation, e | the Belimo star uced for VAV un on the sensors, documentatior .g. LMV-D3-MP | idard version, there is also t it manufacturers. These ver damper shafts and fastenin h. ABC (ABC = customer desig | he VAV-Compact in OEM ver sions receive OEM-specific a g systems used. See VAV uni gnation) | sions, i.e. djustment ts | | | |
| Other versions | The VAV-Compact is also available with built-in interface for direct integration in KNX, BACnet and Modbus. For more information please visit your local website. | | | | | | | |



Safety notes

- Ŵ
- The device is not allowed to be used outside the specified field of application, especially not in aircraft or in any other airborne means of transport.
- Outdoor applications: Only possible if no (sea) water, snow, ice, solar radiation or aggressive gases act directly on the actuator and it is guaranteed that the ambient conditions are always within the limit values according to the data sheet.
- Only authorised specialists may carry out installation. All applicable legal and government agency regulations must be complied with during use.
- The device may be opened only at the manufacturer's plant. It does not contain any parts that can be replaced or repaired by the user.
- Cables must not be removed from the device.
- When calculating the torque requirement, the specifications supplied by the damper manufacturers (cross-section, construction, installation situation), and the ventilation conditions must be observed.
- The device contains electrical and electronic components and is not permitted to be disposed of as household waste. Local and currently valid legislation must be observed.

Electrical installation



See separate documentation for description of function and application

Volumetric flow compact control device for analogue and MP-Bus control



| Technical data | | |
|-----------------------------|---|--|
| Electrical data | Nominal voltage | AC/DC 24 V, 50/60 Hz |
| | Operating range | AC 19.228.8 V/DC 21.628.8 V |
| | Performance data | See type overview (page 1) |
| | Connection | Cable, 4 x 0.75 mm ² , pre-fabricated |
| Volumetric flow controller | Control function | VAV/CAV and pacition control (Open Leon) |
| | $\frac{1}{V'}$ 1) | Nominal flow rate setting OEM-specific matches the VAV unit |
| | $\frac{\mathbf{v} \text{ nom }^{(\prime)}}{\mathbf{\Delta p} \otimes \mathcal{V}^{\prime}} = 1$ | |
| | V' | 20.100% of V' adjustable |
| | V max | $\sum V' = \langle V' \rangle$ adjustable |
| | | $\sim v \min \ldots < v \max$, aujustable |
| Analagua control VAV | • min | |
| Analogue control - VAV | Mode (Y) | Input impedance 100 k Ω (0/420 mA with 500 Ω resistance) |
| | Actual value signal (U) | 010 V/210 V, max. 0.5 mA Volumetric flow / Damper position / Δp, reversible |
| Step control - CAV | Operating modes | CLOSE / V' _{min} / V' _{mid} *) / V' _{max} / OPEN *) *) AC 24 V supply required |
| Bus mode | Communication | Belimo MP-Bus |
| | Addressing | MP18 (analogue control: PP) |
| | Bus Client | DDC with MP interface (see list Belimo-MP-Partner www.belimo.com) |
| | Control | Setpoint specification in % between the set V'min/V'max values |
| | Sensor integration | Passive sensor (Pt1000, Ni1000) or active sensor (010 V) |
| | | Switching contact (0/1) (switching capacity 16 mA @ 24 V) |
| Operation and service | Assistant App (Smartphone) | Contactless connection via integrated NFC interface |
| | Service Tool ZTH EU, PC-Tool | Local connector socket / Remote via PP/MP connection or MP client |
| | LED | Supply, status and communication display |
| | Push-button | Addressing, angle-of-rotation adaptation and test function |
| Actuator | Rotary / Linear version | Brushless, blockage-proof actuator with power-save mode |
| | Direction of rotation ¹⁾ | Left/right or up/down, adjustable |
| | Angle of rotation | 95° or 150 / 200 / 300 mm stroke, |
| | - | adjustable mechanical or electrical limitation |
| | Gear disengaged | Push button, self-resetting without functional limitation |
| | Position indication | Mechanical or for read-out (Tool, Bus Client) |
| | Shaft holder | Shaft clamp for round and square axes, form fit, OEM versions |
| /olumetric flow measurement | Differential pressure sensor | Belimo D3 sensor, dynamic measurement principle |
| | Measurement, nominal voltage range | -20500 Pa, 0500 Pa |
| | Overload capacity | ±3000Pa |
| | Altitude compensation | Adaptation to system altitude (adjustment range 03000 meters above sea level) |
| | Installation position | Position-independent, no reset necessary |
| | Materials in contact with measuring materials | Glass, epoxy resin, PA, TPE |
| | Condition of measuring air | Comfort zone 050°C / 595% RH, non-condensing |
| Security | Protection class IEC/EN | III Protective extra low voltage (PELV) |
| | Degree of protection IEC/EN | IP54 |
| | EMC | CE according to 2014/30/EU |
| | Certification IEC/EN | IEC/EN 60730-1 and IEC/EN 60730-2-14 |
| | Rated impulse voltage Supply / Control | 0.8 kV |
| | Control pollution degree | 3 |
| | Ambient temperature | 050°C |
| | Storage temperature | -40 80°C |
| | Ambient humidity | 95% BH non-condensing |
| | Maintenance | Maintenance-free Depending on use the differential pressure nickup device |
| | mantenance | (measuring cross, disc, etc.) of the VAV unit must be checked now and then and cleaned as needed. |

¹⁾ Setting by VAV manufacturer (OEM)

FCC: See US-relevant notes on page 12

Volumetric flow compact control device for analogue and MP-Bus control





ABL

set to 0.5 V, because otherwise the open connection 3 will be interpreted as damper CLOSE.

CAV - Step mode CLOSE / V'min / V'mid / V'max / OPEN

Wiring diagram

T

M

M

For CAV applications, the shut-off level must not be

CAN control The VAV-Compact can be adapted for constant volumetric flow applications with the PC-Tool, "CAV function" option on the desired CAV function template:

– Damper CLOSE – V'_{min} – V'_{max} – Damper OPEN (default)

Tool / Actual value signal

- Damper CLOSE - V'min - V'mid - V'max - Damper OPEN (NMV-D2M-compatible)

Notes

- Note that the contacts are mutually interlocking.
- DC supply: * c and e are not available with DC
- 24 V.
- Setting parameters for CAV application: Mode 2...10 V, shut-off level 0.1 V The shut-off level cannot be set to 0.5 V with CAV applications, because otherwise the open connection 3 will be interpreted as damper CLOSE.

| rcuit rminal 3 | | 3 | | | 3 |
|-------------------|---------------------|-------------------|-----------|---------------------|------------|
| ode 210 V | CLOSE | V' _{min} | CLOSE * | V' _{max} | OPEN * |
| ode 010 V | V'min | V' _{min} | CLOSE * | V' _{max} | OPEN * |

| CAV | function | CLOSE - | V'min – | V'mid – | V'max – |
|-----|----------|---------|---------|---------|---------|
| | | | | | OPEN |

| | а | b | с | d | е |
|-------------------------------------|--------------------------|-------------------|---------------------|--------------------------|---------------|
| Signal | L | | ~ | ~ | ~ |
| | - | | | + | |
| Protective circuit terminal 3 | | 3 | <u>本</u> 」 3 | | <u>↓</u> 3 |
| Mode 210 V | CLOSE | V' _{min} | V' _{mid} * | V' _{max} | OPEN * |
| Mode 010 V | V'min | V' _{min} | V'mid * | V' _{max} | OPEN * |

Belimo PC-Tool setting "CAV function": 2...10 V, Shut-off level 0.1 V

ABL

U

Belimo PC-Tool setting "CAV function":

CLOSE - V'min - V'max. Shut-off level CLOSE: 0.1 V

Belimo PC-Tool setting "CAV function": CLOSE – V'_{min} – V'_{mid} – V'_{max} (NMV-D2M-compatible)

Volumetric flow compact control device for analogue and MP-Bus control



MP-Bus mode - VAV/CAV function

Connection on the MP bus



Connection of active sensors



Connection of passive sensors



| Ni1000 | –28+98°C | $8501600 \ \Omega^{2)}$ |
|--------|-------------------------|--------------------------|
| PT1000 | –35+155°C | 8501600 Ω ²⁾ |
| NTC | -10+160°C ¹⁾ | 200 Ω60 kΩ ²⁾ |

A) Additional actuators and sensors

A) Additional actuators and sensors

(max. 8)

(max. 8)

Supply AC/DC 24V

(max. DC 0 ... 32 V)

· Resolution 30 mV

Output signal DC 0 ... 10 V

Local override control

If no sensor is integrated, then connection 3 (Y) is available as the protective circuit for a local override control. Options: CLOSE - V'max - OPEN

Caution: Functions only with AC 24 V supply!



See www.belimo.com / Bus and System Integration for more detailed information regarding MP-Bus and installation (max. signal cable lengths, etc.)



There are no restrictions for the network topology (star, ring, tree or hybrid forms are permissible). Supply and communication in one and

the same 3-wire cable

- no shielding or twisting necessary
- No terminating resistors required

Connection of external switching contact



A) Additional actuators and sensors (max. 8)

- Switching current 16 mA @ 24 V
- Start point of the operating range must be parameterised on the MP actuator as ≥0.5 V

A) Additional actuators and sensors (max. 8)

1) Depending on type

2) Resolution 1 Ohm



Control functions - VAV/CAV





Damper CLOSE via 0...10 V reference signal (Mode 2...10 V)



Description:

Setting parameters: Mode 2...10 V, shut-off level 0.1 V or 0.5 V

If the necessary switching threshold of 0.1 V cannot be achieved, then the value can be changed to 0.5 V with the PC-Tool.

| Function | Default 0.1 V | Shut-off level 0.5 V | | |
|-------------------|---------------|----------------------|--|--|
| Damper CLOSED | <0.1 V | <0.5 V | | |
| V' _{min} | >0.12 V | >0.52 V | | |
| V'minV'max | 210 V | 210 V | | |

For CAV applications, the shut-off level must not be set to 0.5 V, because otherwise the open connection 3 will be interpreted as damper CLOSE.

CAV Operating volumetric flow setting



Open Loop (separate external VAV control)



Volumetric flow sensor value





Settings and tool functions

| Designation | Setting values, limits, explanations | values limits explanations | | | Bemarks | |
|--|--|--|---|-----------------------------|--------------------------------------|---|
| Doolghadon | | | Assistant app | ZTH EU | PC-Tool | |
| System-specific data | 1 | | | 1 | | 1 |
| Position | 16 characters, e.g. Office 4 6th OG ZL | Text | r/w | r | r/w | |
| Designation | 16 characters: Unit designation, etc. | Text | r | r | r/w | |
| Address | PP / MP18 | | r/w ³⁾ | r/w | r/w | PP: 010 / 210 V MP18: MP mode |
| V' _{max} | 20100% [V'nom] | m³/h / l/s / cfm | r/w | r/w | r/w | >/=V'min |
| V' _{mid} | V'minV'max | m³/h / l/s / cfm | r/w | r/w | r/w | |
| V'min | 0100% [V'nom] | m³/h / l/s / cfm | r/w | r/w | r/w | =V'max</td |
| Altitude of installation | 03000 | Meter | r/w | r/w | r/w | Adaptation of ∆p sensor to altitude (meters above sea level) |
| Controller Settings | 1 | | 1 | 1 | | |
| Control function | Volumetric flow / Position control (Open Loop) | | r/w ³⁾ | | r/w | |
| Mode | 010/210 | Volt | r/w ³⁾ | r/w ³⁾ | r/w | |
| CAV function | CLOSE/V'min/V'max; Shut-off level CLOSE 0.1 V CLOSE/V'min/V'max; Shut-off level CLOSE 0.5 V V'min/V'mid/V'max; (NMV-D2M-comp.) | | | | r/w | For explanation, see ⁴⁾ |
| Positioning signal Y | Start value: 030; Stop value: 232 | Volt | r | r | r/w | |
| Feedback U | Volume / Damper position / Δp | | | | r/w | Definition of feedback signal |
| Feedback U | Start value: 0.08.0; Stop value: 2.010 | Volt | | | r/w | |
| Behaviour when switched on (Power-on) ⁶⁾ | No action / Adaptation / Synchronisation | | | | r/w | |
| Synchronisation behaviour | Y=0% Y=100% | | | - | r/w | Synchronisation at damper position 0 or 100% |
| Bus fail position | Last setpoint / Damper CLOSE V'min / V'max / Damper OPEN | | | | r/w | |
| Unit-specific settings | | | | | | |
| V'nom | 060000 m ³ /h | m³/h / l/s / cfm | r | r | r/(w) 1) | Unit-specific setting value |
| Δp@V' _{nom} | 38450 Pa | Pa | r | r | r/(w) 1) | Unit-specific setting value |
| NFC interface | Read / Read and write | | r | | r/(w) ¹⁾ | |
| Print function label | | | | | w | Incl. customer logo |
| Other settings | 1 | | 1 | 1 | 1 | |
| Direction of rotation (for Y=100%) | cw/ccw or ▲/▼ | | r/w ³⁾ | r/w ³⁾ | r/w | |
| Range of rotation | Adapted ⁵⁾ / programmed 3095 | • | | | r/w | |
| Torque | 100 / 75 / 50 / 25 | % | | | r/w | % of nominal torque |
| Renovation of old systems | (Retrofit of old VAV units with leaking damper) | | 1 | I | | |
| Suppress damper leakage | Yes/No | | | | r/(w) ²⁾ | Suppresses volume display with damper closed |
| Operating data | 1 | | 1 | 1 | 1 | |
| Actual value / Setpoint Damper position | | m³/h / l/s / cfm Pa / % | r Trend | r | r Trend | Trend display |
| Simulation | Damper OPEN/CLOSE V'min / V'mid / V'max / Motor Stop | | | w | w | |
| Running times | Operating time, Running time Ratio (relation) | h % | r | | r | |
| Alarm messages | Setting range enlarged, Mech. overload, Stop&Go ratio too high | | | | r/w | |
| Serial number | Device ID | | r | r | r | Incl. production date |
| Туре | Type designation | | r | r | r | |
| Version display | Firmware, Config. table ID | | | r | r | |
| Configuration data | | | | | | |
| Print, send | | | yes | | yes | |
| Backup in file | | | yes | | yes | |
| Log data / Logbook | Activities log | | | | yes | Incl. complete setting data |
| Explanations | Write function accessible only for VAV manufacturers Parameters accessible only for VAV manufacturers and Access only via servicing level 2 Shut-off level 0.1/0.5 V – Application: VAV mode, in the threshold of 0.1 V cannot be achieved, then the thresh When line 3 (Y) is open, "Damper CLOSE" is activated i Within the mechanical limitation. The first time the supply voltage is switched on i.e. at | Retrofit partners mode 210 V, "Dam old can be changed to nstead of "V'min". | per CLOSE" via 0 0.5 V. Note or missioning, the | 010 V contr CAV applicat | ol signal. If the ion: The shut-c | e necessary switching ff level must not be set to 0.5 V. ption, which is when the |

operating range and position feedback adjust themselves to the mechanical setting range. The actuator then moves into the required position in order to ensure the volumetric flow defined by the control signal. ⁷) For function and version overview, see www.belimo.com.

No power supply or fault

1 Push-button and LED display green

Off:



Display and operation



| | On: Press button: | Operation Switches on angle-of-rotation adaptation |
|----|---|---|
| 2 | Push-button and Off: Flickering: On: Flashing: Press button: | LED display yellow Normal operation MP communication active Adaptation or synchronising process active Addressing request sent to MP client Confirmation of addressing |
| 3 | Gear disengagen Press button: Release button: | nent button Gear disengaged, motor stops, manual override possible Gear engaged, synchronisation starts, followed by standard mode |
| 4 | Service plug | For connecting the parametrisation and service tools |
| 5 | NFC Logo | Can be operated with Belimo Assistant App |
| MP | -Bus mode: Incor | rect wiring display |
| 1 | Off and 2 On | AC supply: Connections 1 ($f L$) and 2 (\sim) switched |
| 1 | Off and 2 Off | DC supply: Connections 1 (–) and 2 (+) switched |

NFC, Smartphone – Belimo Assistant App



Equipment marked with the NFC logo can be operated contact-free via the NFC interface with the Belimo Assistant App

(...MV-D3-MP starting with year of manufacture 2015).

The test is run once after the 24 V supply is switched on.

For this check, the MP client must be connected with the VAV-Compact.

Prerequisites:

- Android or iOS Smartphone
- ZIP-BT-NFC for Bluetooth connection for Smartphone without NFC (iOS Android)
- Belimo Assistant App (Google Play / App Store)

The optimum reception range is within the antenna range indicated by arrows. Align Smartphone or ZIP-BT-NFC on the VAV-Compact in such a way that the two NFC antennas are on top of one another.



ZTH EU / PC-Tool - Local service connection

Setting and diagnostics of the VAV-Compact can be carried out quickly and easily with the Belimo PC-Tool or the ZTH EU service tool. When the PC-Tool is used, the ZTH EU acts as the interface converter.



Download Belimo PC-Tool (MFT-P) from www.belimo.com



Display and operation

ZTH EU / PC-Tool - Remote connection

The VAV-Compacts can communicate with the service tools via the MP connection (wire 5). The connection can be made during operation at the connector socket, at the tool connector socket of the CR24 room controller or at the switchbox terminals. In MP-Bus mode, the Tool is connected at the MP client. The ZTH EU is used as interface converter with the PC-Tool is used.



Accessories

| Room controller | Description | Туре | | | | |
|---------------------------|--|------------|--|--|--|--|
| (210 V control) | Room temperature controller, AO: VAV; DI: Standby/EHO/C-O | CR24-B1 | | | | |
| | Room temperature controller, AO: VAV/HZ 3-point; DI: Standby/EHO/Ventilation | CR24-B2 | | | | |
| | Room temperature controller, AO: VAV/HZ EI-LE; DI: Standby/EHO/Boost | CR24-B2E | | | | |
| | Room temperature controller, AO: VAV/HZ 3-point; H/K 010 V; DI: Standby/EHO/C-O/Boost | CR24-B3 | | | | |
| | Apartment ventilation controller, AO: 2 x VAV/HZ valve; DI: EHO/override Kitchen+Bath | CRA24-B3 | | | | |
| | Step control, 3-step (Min/COMF/Max) | CRA24-B1P | | | | |
| | Positioner, 0100% | CRP24-B1 | | | | |
| Gateways | Description | Туре | | | | |
| | Gateway MP to BACnet MS/TP, AC/DC 24 V | UK24BAC | | | | |
| | Gateway MP to Modbus RTU, AC/DC 24 V | UK24MOD | | | | |
| VAV-Compact/VAV-Universal | Description | | | | | |
| | VAV-Compact: Version with integrated BACnet, Modbus and KNX interface | | | | | |
| | VAV-Universal: VAV / pressure controller incl. Δp sensors, actuators (fail-safe, fast running actuator, etc.) | | | | | |
| | For more information please visit your local website. | | | | | |
| Electrical accessories | Description | Туре | | | | |
| | Connection cable 5 m, to ZTH EU / ZIP-USB-MP (RJ12) with service plug | ZK1-GEN | | | | |
| | Connection cable 5 m, to ZTH EU / ZIP-USB-MP (RJ11) with free wire ends | ZK2-GEN | | | | |
| Service tools | Description | Туре | | | | |
| | Service tool, with ZIP-USB function, for parametrisable and communicative actuators, VAV controllers and HVAC performance devices from Belimo | ZTH EU | | | | |
| | Belimo PC-Tool, software for adjustments and diagnostics, Belimo Assistant App, for Android or iOS Smartphone, free download at Google Play/App Store | MFT-P | | | | |
| | Bluetooth / NFC converter | ZIP-BT-NFC | | | | |
| | Adapter for ZTH service tool EU | MFT-C | | | | |

Volumetric flow compact control device for analogue and MP-Bus control



Dimensions [mm]

Dimensional drawings LMV-D3-MP





Dimensional drawings SMV-D3-MP



Dimensional drawings LHV-D3-MP



| Туре | Max. stroke | Α | В |
|--------------|-------------|-------|-------|
| LHV-D3-MP100 | 100 | 233.5 | 264.2 |
| LHV-D3-MP200 | 200 | 333.5 | 364.2 |
| LHV-D3-MP300 | 300 | 433.5 | 464.2 |



FCC notes (relevant only for US market)

This device complies with part 15 of the FCC:

Operation is subject to the following two conditions:

- 1. This device may not cause harmful interference
- 2. This device must accept any interference received, including interference that may cause undesired operation.

The following statement applies to the products covered in this manual, unless otherwise specified herein. The statement for other products will appear in the accompanying documentation.

NOTE:

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation.

If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio / T.V. technician for help.

Further documentations

- Brochure Belimo volumetric flow and pressure control
- Technical data sheet VAV-Compact-MP
- Brochure Overview Bus solutions from Belimo
- Tool connections

VAV-Compact Model overview / Function comparison



| | -MF | -MP | -KNX | -MOD |
|--|----------------|--------------------------------------|--|--|
| | | MP 27 BUS | KNX [®] | ₩ <mark>BACne</mark> t Modbus |
| Field of application: Supply air/Extract air in the comfort zone and in sensor- compatible media | х | х | х | Х |
| AC/DC 24 V supply | Х | Х | Х | Х |
| Δp Sensor installed, dynamic D3, measuring range: | -20500 Pa | -20500 Pa | -20500 Pa | -20500 Pa |
| Actuator variants: – Rotary actuator – Linear actuator | 5 / 10 Nm - | 5 / 10 / 20 Nm 150 / 200 / 300 mm | 5 / 10 / 20* Nm 150* / 200* / 300* mm | 5 / 10 / 20* Nm 150* / 200* / 300* mm |
| VAV-Function Close, V'minV'max | Х | Х | Х | Х |
| CAV steps V'min / V'mid / V'max / Close | Х | Х | - | - |
| Position Control (Open Loop / External V control) | Х | Х | Х | Х |
| DCV (Optimiser function) | - | DDC MP Partner | Yes, programmable | Yes, programmable |
| Analogue control | 0/210 V | 0/210 V | - | 0/210 V |
| Bus actuation | - | Х | Х | Х |
| Bus specification | - | Belimo MP-Bus | KNX S-Mode | Modbus RTU/ BACnet MS/TP/ RS485 |
| Direct integration DDC MP-Partner | - | Х | - | - |
| Integration via Gateway – BACnet – KNX – Modbus RTU | - | X X X | - | - |
| Number of bus subscribers | - | 8 per string | 64 per line segment | 32 per string |
| Sensor integration – Passive (resistance) – Active (010 V) – Switching contact | - | X X X | - X X | - X X |
| Optional control function | - | - | - | - |
| Local override | - | CLOSE / V'max / OPEN | CLOSE / V'max / OPEN | CLOSE / V'max / OPEN |
| Aids | - | MP-Bus tester MP monitor | ETS Product database | - |
| Integration tool | PC-Tool | PC-Tool | ETS | |
| TypeList function (Retrofit, OEM) | - | Х | (-) | (-) |
| Tool connection (U – PP/MP) | РР | PP/MP | РР | PP |
| Service socket ZTH EU/PC-Tool | Х | Х | Х | Х |
| NFC interface | - | Х | - | - |
| Assistant app | - | Х | - | - |
| Service tool ZTH EU | Х | Х | Х | Х |
| PC-Tool – Parameters – Save data – Trend, Logbook – Label print | X | Х | X | X |

* on request