

Modbus Interface Description



Flow Sensor 22PF-1U..

Edition 2023-05 / V4.0



Contents

| Modbus general notes | | |
|-----------------------|-----------------------------------|------|
| | General information | |
| | Modbus RTU | |
| | Parametrisation | |
| | Register implementation | 4 |
| | Standard commands | |
| | Command "Read Discrete Inputs" | |
| | Interpret values in the registers | |
| | 32-bit values in two registers | 5 |
| Modbus register overv | riew | |
| | Operation, Accumulation | 6 |
| | Service | 7 |
| Modbus register desci | ription | |
| | | 8-10 |



Modbus general notes

General informationDate15.12.2022Product NameFlow Sensor

Product Model Number 22PF-x1(X)Ux2(x3(x4))-(SG)

X1: 1, 5

x2: C, D, E, F, G, H, H x3: H, N, K

x4: H. T

Protocol Modbus RTU over RS-485

Modbus RTU Transmission Formats 1-8-N-2, 1-8-N-1, 1-8-E-1, 1-8-O-1

(Default: 1-8-N-2)

Baud Rates 9'600, 19'200, 38'400, 76'800, 115'200 Bd

(Default: 38'400)

Address 1...247 (Default: 1)

Number of Nodes Max. 32 (without repeater)

Terminating Resistor 120 Ω

ParametrisationToolBelimo Assistant App

Register implementation All data is arranged in a table and addressed by 1...n (Register No.) or 0...n-1

(Address). No distinction is made between data types (Discrete Inputs, Coils, Input Registers and Holding Registers). As a consequence, all data can be accessed with the two commands for Holding Register. The commands for

Discrete Inputs and Input Registers can be used as an alternative.

Standard commands Read Holding Registers [3]

Write Single Register [6] Read Discrete Inputs [2] Read Input Registers [4] Write Multiple Registers [16]

Command

"Read Discrete Inputs"

The command reads one or more bits and can alternatively be used for Register No. 105 (Malfunction and Service Information).

Example:

The start address to be used is 1664 -> 104 (Register No.) * 16 (Bit) = 1664

Interpret values in the registers

All values in the register are unsigned integer data types.

Exeptions are marked with **). Signed integers are represented as two's complement.

Example unsigned integer: Example signed integer: Read (Function 03, 1 Register) Read (Function 03, 1 Register) Value Register No. x Value Register No. x = 0001 1010 1100 10002 = 1111 1101 1111 00102 = -526₁₀ $= 6,856_{10}$ Actual value Actual value = value * scaling factor * unit = value * scaling factor * unit = 6,856 * 0.01 * unit = -526 * 0.01 * unit = 68.56 unit = -5.26 unit

32-bit values in two registers

Values that exceed 65,535 are stored in two Consecutive Registers and have to be interpreted as "little endian byte swap" / LSW (Least Significant Word) first.

Example:

Register No. x (Value LowWord) Register No. x + 1 (Value HighWord) = $14,551_{10}$ = 19_{10} = $0001 \ 1000 \ 1101 \ 0111_2$ = $0000 \ 0000 \ 0001 \ 0011_2$

Value LowWord

= 14,551 = 0011 1000 1101 0111₂ Value HighWord

= 19

= 0000 0000 0001 00112

32-bit value

- = 0000 0000 0001 0011 0011 1000 1101 01112
- $= 1,259,735_{10}$
- = 1,259.735 unit

Math formula:

32-bit value = (Value HighWord * 65,536) + Value LowWord 32-bit value = (19 * 65,536) + 14,551 = 1,259,735

- 1,209,700

= 1,259.735 unit

Deactivated registers

If a register is not supported by a device or by a device setting, this is indicated by 65,535 (1111 1111 1111 1111₂).



All writeable registers >100 are persistent and are not supposed to be written on a regular basis.

Modbus register overview

Operation

| No. | Address | Register | | Access |
|-----|---------|---|----------|--------|
| | | - | | - |
| 7 | 6 | Relative Volumetric Flow [%] | | R |
| 8 | 7 | Absolute Volumetric Flow [l/s] | | R |
| 9 | 8 | Absolute Volumetric Flow [gpm] | | R |
| 10 | 9 | LowWo | LowWord | |
| 11 | 10 | Absolute Volumetric Flow in unit selected | HighWord | - R |
| | | - | | - |
| 13 | 12 | Sensor Value [mV] [-] | | R |
| | | - | | - |
| 22 | 21 | T_C **) | | R |
| 23 | 22 | T_F **) | | R |
| 26 | 25 | Glycol Concentration [%] | | R |

 $^{^{\}star\star)}$ signed integer

Accumulation

| No. | Address | Register | | Access | |
|-----|---------|--------------------------------|----------|--------|--|
| 60 | 59 | | LowWord | | |
| 61 | 60 | Total Volume m ³ | HighWord | - R | |
| 62 | 61 | | LowWord | | |
| 63 | 62 | Total Volume gal | HighWord | - R | |
| 64 | 63 | | LowWord | | |
| 65 | 64 | Total Volume in selected units | HighWord | - R | |

Service

| No. | Address | Register | , | Access | |
|-----|---------|--|----------|--------|--|
| 100 | 99 | Bus Termination | | | |
| 101 | 100 | Series Number 1 st part | | | |
| 102 | 101 | Series Number 2 nd part | | R | |
| 103 | 102 | Series Number 4 th part | | - | |
| 104 | 103 | Firmware Version | | - | |
| 105 | 104 | Malfunction and Service Information | | R | |
| | | - | | - | |
| 111 | 110 | FS (full scale, max. flow) in I/s | | R | |
| 112 | 111 | FS (full scale, max. flow) in gpm | | R | |
| 113 | 112 | | LowWord | D | |
| 114 | 113 | FS (full scale, max. flow) in selected units | HighWord | - R | |
| | | - | | - | |
| 121 | 120 | Sensor 1 Type | | R/W | |
| | | - | | - | |
| 148 | 147 | Unit Selected Flow | | R/W | |
| 150 | 149 | Unit Selected Volume | | R/W | |
| | | - | | - | |
| 201 | 200 | M. O. I.N. 5. I.D. I | LowWord | | |
| 202 | 201 | Meter_Serial_No First Part HighWord | | - R | |
| 203 | 202 | Mater Carial Na Occasi d Dart | LowWord | | |
| 204 | 203 | Meter_Serial_No_Second Part — Hig | | - R | |

Modbus register description

| No. | Address | Description Comment | Range, enumeration | Unit | Scaling | Access |
|-----|---------|--|--------------------------------|---------|-----------|--------|
| 7 | 6 | Relative Volumetric Flow Relative to FS | 015'000 | % | 0.01 | R |
| 8 | 7 | Absolute Volumetric Flow | 010′000 | I/s | 0.01 | R |
| 9 | 8 | Absolute Volumetric Flow | 016'000 | gpm | 0.1 | R |
| 10 | 9 | Absolute Volumetric Flow in selected units | 0360'000'000 | UnitSel | 0.001 | |
| 11 | 10 | -> based on selection in Register No. 148 | Actual range determined | UnitSei | 0.001 | R |
| 13 | 12 | Sensor Value 1 | 065'535 | mV | 1 0 /1 | R |
| | | - | - | - | - | - |
| 22 | 21 | T_C | -2'00012'000 | °C | 0.01 | R |
| 23 | 22 | T_F | -40024'800 | °F | 0.01 | R |
| 26 | 25 | Glycol Concentration | 010′000 | % | 0.01 | R |
| | | - | - | - | - | - |
| 60 | 59 | | | m³ | 0.01 | R |
| 61 | 60 | - Total Volume | 02'147'483'600 | III. | 0.01 | K |
| 62 | 61 | | 0.004.474.0046.47 | anl | 1 | R |
| 63 | 62 | - Total Volume | 02'147'483'647 | gal | ı | ц |
| 64 | 63 | - Total Volume in selected units | 02'147'483'647 Actual range | | | |
| 65 | 64 | -> based on selection in Register No. 150 | determined by selected unit | UnitSel | 1 | R |
| | | | | | | |

| No. | Address | Description Comment | Range, enumeration | Unit | Scaling | Access |
|-----|---------|---|--|---------|---------|--------|
| 100 | 99 | Bus Termination Indicates if bus termination (120Ω) is enabled. Bus termination can be set by configuration tools. | 0: Disabled 1: Enabled Default: 0 | - | - | R |
| 101 | 100 | Series Number 1st part Each device has an unambiguous series number, which is either impressed on or glued to the housing. The series number consists of 4 segments, although only parts 1, 2 and 4 are displayed on Modbus. Example 00839-31324-064-008 1st part: 00839 2nd part: 31324 4th part: 008 | | - | - | R |
| 102 | 101 | Series Number 2 nd part | - | - | - | R |
| 103 | 102 | Series Number 4 th part | - | - | - | R |
| 104 | 103 | Firmware Version | - | - | - | R |
| 105 | 104 | Malfunction and Service Information Value ist bit-coded. More than one bit can be set to 1. All bits not mentioned in the enumeration are not used for this actuator range. | Bitmask = 0: - 1: - 2: - 3: Reverse flow 4: - 5: - 6: Flow actual exceeds FS 7: Flow measurement error 8: - 9: Flowbody temperature error 10: Communication to sensor interrupted 11: Freeze warning 12: Glycol detected | | - | R |
| | | - - | - | - | _ | - |
| 111 | 110 | FS (full scale, max. flow) | 010′000 | l/s | 0.01 | R |
| 112 | 111 | FS (full scale, max. flow) | 016'000 | gpm | 0.1 | R |
| 113 | 112 | FS (full scale, max. flow) in selected units -> based on selection in Register No. 148 | 0360'000'000 Actual range determined by | UnitSel | 0.001 | R |
| 114 | 113 | -> based on selection in Register No. 148 | selected unit | | _ | |
| | | - - | - | - | - | - |
| 121 | 120 | Sensor 1 Type Additional sensor input | 0: None 1: Active 2: - 3: - 4: Switch Default: 0 | - | - | R/W |
| | | - | | - | - | - |
| | | - | | | | |

| No. | Address | Description Comment | Range, enumeration | | Unit | Scaling | Access |
|-----|---------|---------------------------------|---|--|------|---------|--------|
| 148 | 147 | Unit Selection Flow | 0: m³/s 1: m³/h 2: l/s 3: l/min | 4: I/h 5: gpm 6: cfm Default: 4 | - | - | R/W |
| | | - | - | | - | - | - |
| 150 | 149 | Unit Selection Volume | 0: m³ 1: Litre 2: Gallon 3: cf Default: 0 | | - | - | R/W |
| | | - | - | | - | - | - |
| 201 | 200 | Meter Serial Number First Part | | | | | |
| 202 | 201 | ProductionOrderNumber | <u>-</u> | | - | I | R |
| 203 | 202 | Meter Serial Number Second Part | | | _ | 1 | R |
| 204 | 203 | ProductionSequenceNumber | | | | | |

All inclusive.

Belimo as a global market leader develops innovative solutions for the controlling of heating, ventilation and air-conditioning systems. Damper actuators, control valves, sensors and meters represent our core business.

Always focusing on customer value, we deliver more than only products. We offer you the complete product range for the regulation and control of HVAC systems from a single source. At the same time, we rely on tested Swiss quality with a five-year warranty. Our worldwide representatives in over 80 countries guarantee short delivery times and comprehensive support through the entire product life. Belimo does indeed include everything.

The "small" Belimo devices have a big impact on comfort, energy efficiency, safety, installation and maintenance.

In short: Small devices, big impact.



5-year warranty



On site around the globe



Complete product range



Tested quality



Short delivery times



Comprehensive support



